




CAL-TECH TESTING, INC.

ENGINEERING & TESTING LABORATORY

P.O. Box 1625, Lake City, FL 32056-1625
2907 Spring Glen Road • Jacksonville, FL 32207

Lake City • (386) 755-3633
Fax • (386) 752-5456

Jacksonville • (904) 381-8901
Fax • (904) 381-8902

JOB NO.: 24-482
DATE TESTED: 9-23-24

REPORT OF IN-PLACE DENSITY TEST

ASTM METHOD: (D-2922) Nuclear (D-2937) Drive Cylinder Other

PROJECT: 418 SE Robin Hood Pl.

CLIENT: Robin Parker

GENERAL CONTRACTOR: SAC EARTHWORK CONTRACTOR: SAC

SOIL USE (SEE NOTE): 1 SPECIFICATION REQUIREMENTS: 95

TECHNICIAN: J Green

MODIFIED (ASTM D-1557): STANDARD (ASTM D-698):

TEST NO.	TEST LOCATION	TEST:	PROCTOR NO.	WET DENS. LBS.CU.FT.	DRY DENS. LBS.CU.FT.	MOIST PERCENT	% MAX. DENS.
		DEPTH ELEV. LIFT					
	10 ft NW of SE corner of pad			112.6	104.8	7.4	100
	Middle of pad			114.8	109.6	4.7	104
	10 ft SE of NW corner of pad			114.1	109.4	4.3	104

REMARKS:

PROCTOR NO.	SOIL DESCRIPTION	PROCTOR VALUE	OPT. MOIST.
		105.3	13.3

NOTE: 1. Building Fill 2. Trench Backfill 3. Base Course 4. Subbase/Stabilized Subgrade 5. Embankment 6. Subgrade/Natural Soil 7. Other
The test results presented in this report are specific only to the samples tested at the time of testing. The tests were performed in accordance with generally accepted methods and standards. Since material conditions can vary between test location and change with time, sound judgement should be exercised with regard to the use and interpretation of the data.