Job: J-9735 - C-1309 Date: May 02, 2023 LaTisha Furmon

## **Project Information**

PARRISH RESIDENCE For: 157 SE SHADY WAY, LULU, FL

Notes:

### **Design Information**

Weather: Gainesville Regional, FL, US

### **Winter Design Conditions**

### **Summer Design Conditions**

Outside db Inside db	33 °F Outside db 70 °F Inside db		92 °F 75 °F
Design TD	37 °F	Design TD Daily range	17 °F M
		Relative humidity Moisture difference	50 % 44 gr/lb

### **Heating Summary**

### Sensible Cooling Equipment Load Sizing

Structure	15855	Btuh	Structure	21159 Btuh
Ducts	4344	Btuh	Ducts	6455 Btuh
Central vent (0 cfm)	0	Btuh	Central vent (0 cfm)	0 Btuh
(none)			(none)	
Humidification	0	Btuh	Blower ´	0 Btuh
Piping	0	Btuh		
Piping Equipment load	20199	Btuh	Use manufacturer's data	n
			Rate/swing multiplier	0.97
	Infiltration		Equipment sensible load	26841 Btuh

#### Simplified Method Construction quality Δνίστασα

# Latent Cooling Equipment Load Sizing

Fireplaces		Average 0	Structure Ducts Central vent (0 cfm)		Btuh Btuh Btuh
Area (ft²) Volume (ft³)	<b>Heating</b> 1814 14550	<b>Cooling</b> 1814 14550	(none) Equipment latent load	3788	Btuh
volume (۱۲) Air changes/hour Equiv. AVF (cfm)	anges/hour 0.38 0.20	0.20	Equipment Total Load (Sen+Lat) Req. total capacity at 0.80 SHR	30629 2.8	Btuh ton

### **Heating Equipment Summary**

### **Cooling Equipment Summary**

Trane

Trade TRANE		Irade IRANE		
Model 4TWR4036N1		Cond 4TWR403	6N1	
AHRI ref 209842226			37M31++TDR	
A II (11C) 2000-22220				
		AHRI ref 209842226		
Efficiency	7.5 HSPF2	Efficiency	11.7 EER2,14.3 SEER2	
Heating input		Sensible cooling	27680	Btuh
Heating output	32600 Btuh @ 47°F		6920	Btuh
<u>Heating</u> output		Latent cooling		
Temperature rise	26 °F	Total cooling	34600	Btuh
Actual air flow	1153 cfm	Actual air flow	1153	cfm
			0.042	cfm/Btuh
Air flow factor		Air flow factor		
Static pressure	0.53 in H2O	Static pressure	0.53	in H2O
Space thermostat		Load sensible heat ratio	0.88	
O		Edad Consiste Hour Idao	0.00	

Make

Capacity balance point = 20 °F

Trane

Backup:

Make

Input = 7 kW, Output = 23269 Btuh, 100 AFUE

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



### Manual S Compliance Report Entire House

Job: J-9735 - C-1309
Date: May 02, 2023
By: LaTisha Furmon

# **Project Information**

For: PARRISH RESIDENCE

157 SE SHADY WAY, LULU, FL

### **Cooling Equipment**

#### **Design Conditions**

Outdoor design DB:	92.2°F	Sensible gain:	27614	Btuh	Entering coil DB:	77.9°F
Outdoor design WB:	75.8°F	Latent gain:	3788	Btuh	Entering coil WB:	63.9°F
Indoor design DB:	75.0°F	Total gain:	31402	Btuh	•	

Indoor design DB: 75.0°F Total gain: 31402 Btuh Indoor RH: 50% Estimated airflow: 1153 cfm

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split ASHP

Manufacturer: Trane Model: 4TWR4036N1+TEM4B0C37M31++TDR

Actual airflow: 1153 cfm

Sensible capacity: 27680 Btuh 100% of load Latent capacity: 6920 Btuh 183% of load

Total capacity: 34600 Btuh 110% of load SHR: 80%

#### **Heating Equipment**

### **Design Conditions**

Outdoor design DB: 33.2°F Heat loss: 20199 Btuh Entering coil DB: 68.6°F Indoor design DB: 70.0°F

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split ASHP

Manufacturer: Trane Model: 4TWR4036N1+TEM4B0C37M31++TDR

Actual airflow: 1153 cfm

Output capacity: 32600 Btuh 161% of load Capacity balance: 20 °F Supplemental heat required: 0 Btuh Economic balance: -99 °F

Backup equipment type: Elec strip

Manufacturer: Model:

Actual airflow: 1153 cfm

Output capacity: 6.8 kW 115% of load Temp. rise: 50 °F

Meets all requirements of ACCA Manual S.

Page 1