



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

08/01/2021

Permit # 000042155

L-27828

Bryan Zecher Construction

Re: Lot 3 Meadow Wood

To Whom It May Concern:

The top of the finished slab on said Lot 3 is 163.70 feet. The highest adjacent grade is 162.8 feet. The building permit requires the minimum floor to be 163 feet or 8 inches above the highest adjacent grade. The elevations shown hereon are based on NAVD 88 datum.

