



Britt Surveying and Mapping, LLC
2086 SW Main Blvd Ste 112 • Lake City, FL 32025
386-752-7163 P • 386-752-5573 F • www.brittsurvey.com

02/22/19

L-25673

Re: Lot 31 May-Fair Unit 3

Trent Giebeig Construction

To Whom It May Concern:

The elevation of the finished floor elevation is found to be 155.24 feet. The lowest adjacent grade is found to be 151.48 feet, and the highest adjacent grade is found to be 154.6 feet. The minimum floor elevation required is 153.50 feet. All elevations are shown per the plat datum.

Sincerely,

L. Scott Britt
LS 5757

3-16-23