

# Certificate of Product Ratings

AHRI Certified Reference Number : 211162743    Date : 11-15-2024    Model Status : Production Stopped

AHRI Type : HRCU-A-CB (Split System: Heat Pump with Remote Outdoor Unit-Air-Source)

Outdoor Unit Brand Name : TRANE

Outdoor Unit Model Number (Condenser or Single Package) : 4TWR4036N1

Indoor Unit Model Number (Evaporator and/or Air Handler) : TEM4A0C37S31+TDR

The manufacturer of this TRANE product is responsible for the rating of this system combination.

Rated as follows in accordance with the latest edition of AHRI 210/240 – 2024, Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (A<sub>Full</sub>) – Single or High Stage (95F), btuh : 34000

SEER2 : 14.30

EER2 (A<sub>Full</sub>) – Single or High Stage (95F) : 11.70

Heating Capacity (H1<sub>Full</sub>) – Single or High Stage (47F), btuh : 33000

HSPF2 (Region IV) : 7.50



†"Active" Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale; OR new models that are being marketed but are not yet being produced. "Production Stopped" Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.

Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

The Department of Energy has published updated energy efficiency metrics for central air conditioners and heat pumps. This publication reflects both the 1987 metric (SEER) and the 2023 metric (SEER2). Efficiency requirements are published at 10 C.F.R. 430.32(c). Please refer to [www.AHRI.net.org](http://www.AHRI.net.org) for more information about updated energy efficiency metrics.

## DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at [www.ahridirectory.org](http://www.ahridirectory.org).

## TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

## CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at [www.ahridirectory.org](http://www.ahridirectory.org), click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2024 Air-Conditioning, Heating, and Refrigeration Institute



**CERTIFICATE NO.:**

133761796959524485



**Manual S Compliance Report**  
*Entire House*  
**Air Ducks Heating & Air Conditioning**

Job:  
Date: Sep 17, 2024  
By:

2601 NW 74th Place, Gainesville, Fla 32653 Phone: 352-215-4624 Email: airducksac@gmail.com Web: www.airducksac.com

**Project Information**

For: DWC Construction  
Thornwood lot 22

**Cooling Equipment**

**Design Conditions**

Outdoor design DB:	92.4°F	Sensible gain:	25418	Btuh	Entering coil DB:	77.2°F
Outdoor design WB:	75.8°F	Latent gain:	5258	Btuh	Entering coil WB:	63.6°F
Indoor design DB:	75.0°F	Total gain:	30676	Btuh		
Indoor RH:	50%	Estimated airflow:	1133	cfm		

**Manufacturer's Performance Data at Actual Design Conditions**

Equipment type:	Split ASHP			
Manufacturer:	Trane	Model:	4TWR4036N1+TEM4A0C37S31++TDR	
Actual airflow:	1133	cfm		
Sensible capacity:	23800	Btuh	94% of load	
Latent capacity:	10200	Btuh	194% of load	
Total capacity:	34000	Btuh	111% of load	SHR: 70%

**Heating Equipment**

**Design Conditions**

Outdoor design DB:	33.3°F	Heat loss:	32565	Btuh	Entering coil DB:	67.0°F
Indoor design DB:	68.0°F					

**Manufacturer's Performance Data at Actual Design Conditions**

Equipment type:	Split ASHP			
Manufacturer:	Trane	Model:	4TWR4036N1+TEM4A0C37S31++TDR	
Actual airflow:	1133	cfm		
Output capacity:	33000	Btuh	101% of load	Capacity balance: 33 °F
Supplemental heat required:	0	Btuh		Economic balance: -99 °F

Backup equipment type:	Elec strip			
Manufacturer:		Model:		
Actual airflow:	1133	cfm		
Output capacity:	12.5	kW	131% of load	Temp. rise: 50 °F

Meets all requirements of ACCA Manual S.



# Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form  
RPER 2.0

## Header Information

Contractor \_\_\_\_\_  
Mechanical license# Air Ducks Heating & Air Conditioning  
Building plan # \_\_\_\_\_  
Home address (Street or Lot#, Block, Subdivision) Thornwood lot 22, Entire House

Applicable Attachments  
Manual J1 Form and Worksheet A: ☐ Yes ☐ No  
OEM performance data (heating, cooling, blower): ☐ Yes ☐ No  
Duct distribution sketch: ☐ Yes ☐ No  
IRC Table R301.2 (climate & geographic design criteria) ☐ Yes ☐ No

## HVAC LOAD CALCULATION

(IRC M1401.3)

### Manual J Design Criteria and Loads

#### Location

Elevation 123 ft  
Altitude Correction Factor 1.00  
Latitude 30 °N

#### Summer Design Conditions

Outdoor Cooling Temp 92 °F  
Indoor Cooling Temp 75 °F  
Cooling Temp Diff 17 °F  
Indoor Summer Design RH 50 %  
Coincident Wet Bulb Temp 76 °F

#### Manual J Loads

Total Heat Loss 32565 Btuh  
Sensible Heat Gain 25418 Btuh  
Latent Heat Gain 5258 Btuh  
Total Heat Gain 30676 Btuh

#### Winter Design Conditions

Outdoor Winter Temp 33 °F  
Indoor Winter Temp 68 °F  
Heating Temp Diff 35 °F

The heat loss/gain was calculated in accordance with ACCA Manual J? Y ☒ N ☐

## HVAC EQUIPMENT SELECTION

(IRC M1401.3)

### Heating Equipment

☐ Furnace ☐ Boiler ☒ Electric Heat  
☐ Single Speed ☐ Multi Stage ☐ Modulating

#### Model

Output 33000 Btuh Sizing Value 32565 Btuh  
Supplemental 0 Btuh Sizing Limit 175.0 %  
Heat Load: Capacity 131.3 %

Size Factor is within Manual S Size Limit? Y ☒ N ☐

### Cooling Equipment

☐ Air Conditioner ☒ Heat Pump  
☒ Air-to-Air ☐ Geothermal Open Loop ☐ Geothermal Closed Loop  
☒ Single Speed ☐ Multi Stage ☐ Variable Speed

#### Model

4TWR4036N1+TEM4A0C37S31++TDR  
Sensible 23800 Btuh Sizing Value 30676 Btuh  
Latent 10200 Btuh Sizing Limit 115.0 %  
Total 34000 Btuh Load: Capacity 110.8 %

Size Factor is within Manual S Size Limit? Y ☒ N ☐

## HVAC DUCT DISTRIBUTION DESIGN

(IRC M1601.1)

Design airflow 1133 cfm Longest Supply Duct 340 ft Duct Materials Used  
External Static Pressure (ESP) 0.50 in H2O Longest Return Duct 86.0 ft Trunk Duct: ☒ Duct Board ☐ Sheet Metal  
Component Pressure Loss (CPL) 0 in H2O Total Effective Length (TEL) 426 ft ☐ Flex ☐ Lined Sheet Metal ☐ Other  
Available static pressure (ASP) 0.50 in H2O Friction Rate 0.12 in/100ft Branch Duct: ☐ Duct Board ☐ Sheet Metal  
ESP - CPL = ASP (ASP x 100) / TEL = Friction Rate ☒ Flex ☐ Lined Sheet Metal ☐ Other

Ducts are sized per Manual D? Y ☒ N ☐

I declare the load calculation, equipment selection, and duct system design were rigorously performed based on the building plan listed above and understand the claims made on these forms may be subject to review and verification.

Contractor's printed name: \_\_\_\_\_

Contractor's signature: \_\_\_\_\_ Date: \_\_\_\_\_



Load Short Form  
Entire House  
Air Ducks Heating & Air Conditioning

Job:  
Date: Sep 17, 2024  
By:

2601 NW 74th Place, Gainesville, Fla 32653 Phone: 352-215-4624 Email: airducksac@gmail.com Web: www.airducksac.com

Project Information

For: DWC Construction  
Thornwood lot 22

Design Information

	Htg	Clg	Infiltration	Simplified
Outside db (°F)	33	92	Method	Average
Inside db (°F)	68	75	Construction quality	0
Design TD (°F)	35	17	Fireplaces	
Daily range	-	M		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	29	43		

HEATING EQUIPMENT			COOLING EQUIPMENT		
Make	Trane		Make	Trane	
Trade	SEER 2		Trade	SEER 2	
Model	4TWR4036N1		Cond	4TWR4036N1	
AHRI ref	211162743		Coil	TEM4A0C37S31++TDR	
			AHRI ref	211162743	
Efficiency	7.5 HSPF2		Efficiency	11.7 EER2, 14.3 SEER2	
Heating input			Sensible cooling	23800 Btuh	
Heating output	33000 Btuh @ 47°F		Latent cooling	10200 Btuh	
Temperature rise	27 °F		Total cooling	34000 Btuh	
Actual air flow	1133 cfm		Actual air flow	1133 cfm	
Air flow factor	0.035 cfm/Btuh		Air flow factor	0.045 cfm/Btuh	
Static pressure	0.50 in H2O		Static pressure	0.50 in H2O	
Space thermostat			Load sensible heat ratio	0.83	
Capacity balance point = 33 °F					

Backup:  
Input = 13 kW, Output = 42753 Btuh, 100 AFUE

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Master	320	6516	5126	227	229
WIC 1	48	888	408	31	18
WIC 2	48	66	116	2	5
WC	35	0	0	0	0
Master bath	180	3698	1710	129	76
Living	360	7908	9234	275	412
Laundry	80	2284	1741	79	78
Dining	72	1444	729	50	33
Kitchen	170	620	2094	22	93
Bedroom 2	180	4393	1955	153	87
Bath	54	1262	786	44	35
Hall	30	0	0	0	0
Pantry	42	599	223	21	10
Bed 3	192	2887	1295	100	58

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Entire House	1811	32565	25418	1133	1133
Other equip loads		0	0		
Equip. @ 0.97 RSM			24757		
Latent cooling			5258		
TOTALS	1811	32565	30015	1133	1133

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2024 24.0.02 RSU23127

...irdu\OneDrive\Documents\Wrightsoft HVAC\DWC.rup Calc = MJ8 Front Door faces: N

2024-Nov-15 16:29:51

Page 2



# Project Summary

## Entire House

### Air Ducks Heating & Air Conditioning

Job:  
Date: Sep 17, 2024  
By:

2601 NW 74th Place, Gainesville, Fla 32653 Phone: 352-215-4624 Email: airducksac@gmail.com Web: www.airducksac.com

## Project Information

For: DWC Construction  
Thornwood lot 22

Notes:

## Design Information

Weather: Gainesville, FL, US

### Winter Design Conditions

Outside db 33 °F  
Inside db 68 °F  
Design TD 35 °F

Ventilation Method MJ8

### Heating Summary

Structure 26392 Btuh  
Ducts (R-6.0) 6173 Btuh  
Central vent (0 cfm) 0 Btuh

Humidification 0 Btuh  
Piping 0 Btuh  
Equipment load 32565 Btuh

### Infiltration

Method Simplified  
Construction quality Average  
Fireplaces 0

	Heating	Cooling
Area (ft <sup>2</sup> )	1843	1843
Volume (ft <sup>3</sup> )	15710	15710
Air changes/hour	0.38	0.20
Equiv. AVF (cfm)	99	52

### Heating Equipment Summary

Make Trane  
Trade SEER 2  
Model 4TWR4036N1  
AHRI ref 211162743

Efficiency 7.5 HSPF2  
Heating input  
Heating output 33000 Btuh @ 47°F  
Temperature rise 27 °F  
Actual air flow 1133 cfm  
Air flow factor 0.035 cfm/Btuh  
Static pressure 0.50 in H2O  
Space thermostat  
Capacity balance point = 33 °F

Backup:  
Input = 13 kW, Output = 42753 Btuh, 100 AFUE

### Summer Design Conditions

Outside db 92 °F  
Inside db 75 °F  
Design TD 17 °F  
Daily range M  
Relative humidity 50 %  
Moisture difference 43 gr/lb

### Sensible Cooling Equipment Load Sizing

Structure 17584 Btuh  
Ducts (R-6.0) 7835 Btuh  
Central vent (0 cfm) 0 Btuh

Blower 0 Btuh

Use manufacturer's data n  
Rate/swing multiplier 0.97  
Equipment sensible load 24757 Btuh

### Latent Cooling Equipment Load Sizing

Structure 3741 Btuh  
Ducts 1517 Btuh  
Central vent (0 cfm) 0 Btuh

Equipment latent load 5258 Btuh

**Equipment Total Load (Sen+Lat)** 30015 Btuh  
Req. total capacity at 0.70 SHR 2.9 ton

### Cooling Equipment Summary

Make Trane  
Trade SEER 2  
Cond 4TWR4036N1  
Coil TEM4A0C37S31++TDR  
AHRI ref 211162743

Efficiency 11.7 EER2, 14.3 SEER2  
Sensible cooling 23800 Btuh  
Latent cooling 10200 Btuh  
Total cooling 34000 Btuh  
Actual air flow 1133 cfm  
Air flow factor 0.045 cfm/Btuh  
Static pressure 0.50 in H2O  
Load sensible heat ratio 0.83

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2024 24.0.02 RSU23127


...irdu\OneDrive\Documents\Wrightsoft HVAC\DWG.rup Calc = MJ8 Front Door faces: N

2024-Nov-15 16:29:51

Page 1



## Level 2



**Job #:**  
**Performed for:**  
DWC Construction  
Thornwood lot 22

### Air Ducks Heating & Air Conditioning

2601 NW 74th Place  
Gainesville, Fla 32653  
Phone: 352-215-4624  
www.airducksac.com airducksac@gmail.com

Scale: 1 : 90

Page 1  
Right-Suite@ Universal 2024  
24.0.02 RSU23127  
2024-Nov-15 16:30:03  
...ocuments\Wrightsoft HVAC\DWC.r



**Duct System Summary**  
*Entire House*  
**Air Ducks Heating & Air Conditioning**

Job:  
Date: Sep 17, 2024  
By:

2601 NW 74th Place, Gainesville, Fla 32653 Phone: 352-215-4624 Email: airducksac@gmail.com Web: www.airducksac.com

**Project Information**

For: DWC Construction  
Thornwood lot 22

	<b>Heating</b>	<b>Cooling</b>
External static pressure	0.50 in H2O	0.50 in H2O
Pressure losses	0 in H2O	0 in H2O
Available static pressure	0.50 in H2O	0.50 in H2O
Supply / return available pressure	0.399 / 0.101 in H2O	0.399 / 0.101 in H2O
Lowest friction rate	0.117 in/100ft	0.117 in/100ft
Actual air flow	1133 cfm	1133 cfm
Total effective length (TEL)	426 ft	

**Supply Branch Detail Table**

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Bath	h 1262	44	35	0.217	4.0	0x0	VIFx	23.6	160.0	st1
Bed 3	h 2887	100	58	0.218	7.0	0x0	VIFx	13.0	170.0	st1
Bedroom 2	h 4393	153	87	0.171	8.0	0x0	VIFx	29.0	205.0	st1
Dining	h 1444	50	33	0.166	6.0	0x0	VIFx	35.0	205.0	st1
Kitchen	c 2094	22	93	0.173	7.0	0x0	VIFx	25.0	205.0	st1
Laundry	h 2284	79	78	0.201	6.0	0x0	VIFx	9.0	190.0	st1
Living	c 4617	138	206	0.177	7.0	0x0	VIFx	31.0	195.0	st1
Living-A	c 4617	138	206	0.176	7.0	0x0	VIFx	32.0	195.0	st1
Master	c 2563	113	114	0.128	7.0	0x0	VIFx	51.2	260.0	st1
Master bath	h 3698	129	76	0.123	6.0	0x0	VIFx	54.2	270.0	st1
Master-A	c 2563	113	114	0.122	7.0	0x0	VIFx	46.0	280.0	st1
Pantry	h 599	21	10	0.210	4.0	0x0	VIFx	10.0	180.0	st1
WIC 1	h 888	31	18	0.126	4.0	0x0	VIFx	56.6	260.0	st1
WIC 2	c 116	2	5	0.117	4.0	0x0	VIFx	50.0	290.0	st1

**Supply Trunk Detail Table**

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st1	Peak AVF	1133	1133	0.117	850	14.7	8 x 24	RectFbg	



## Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb2	0x 0	386	323	86.0	0.117	708	10.0	0x 0		VIFx	
rb3	0x 0	328	449	83.2	0.121	420	14.0	0x 0		VIFx	
rb1	0x 0	165	103	68.9	0.146	473	8.0	0x 0		VIFx	
rb4	0x 0	254	258	81.2	0.124	241	14.0	0x 0		VIFx	