

NORTH FLORIDA PROFESSIONAL SERVICES, INC.

Experience. Quality. Commitment.



May 20, 2020

Josh Sparks
Sparks Construction
426 SW Commerce Drive, Suite 130-J
Lake City, FL 32025

SUBJECT: ELEVATION LETTER
Parcel No. 17-3S-16-02168-105
679 Blackberry Court, Lake City, Florida 32055

To Whom It May Concern:

Parcel No. 17-3S-16-02168-105 is located in Flood Zone X. The property naturally slopes south. The structure will be elevated on a concrete pad. Once stormwater reaches an approximate elevation of 105' NAVD, it will overflow the property in question and flow into a low area with extensive storage that lies southeast of the property.

Requirements for the Structure to Be Protected from the Base Flood Event:

The top of the stem wall foundation of the structure shall be at 106.8 feet NAVD and above the highest adjacent natural grade at the proposed building site. Any disturbed area around the proposed structure shall be graded to direct all runoff to the southeast.

Sincerely,

Terry R. White, Jr., P.E.
Water Resources Engineer

Attachment

I certify that the finished floor elevation listed above will protect the structure against water damage from a base flood event, as defined in Article 8 of the Land Development Regulations.

Terry R. White, Jr., P.E.

5/20/20
Date