

COLUMBIA COUNTY BUILDING DEPARTMENT RESIDENTIAL CHECK LIST

MINIMUM PLAN REQUIREMENTS: FLORIDA BUILDING CODE RESIDENTIAL 2017 EFFECTIVE 1 JANUARY 2018
AND THE NATIONAL ELECTRICAL 2014 EFFECTIVE 1 JANUARY 2018

ALL REQUIREMENTS ARE SUBJECT TO CHANGE

ALL BUILDING PLANS MUST INDICATE COMPLIANCE WITH THE CURRENT FLORIDA BUILDING CODES RESIDENTIAL AND THE NATIONAL ELECTRICAL CODE. ALL PLANS OR DRAWINGS SHALL PROVIDE CALCULATIONS AND DETAILS THAT HAVE THE SEAL AND SIGNATURE OF A CERTIFIED ARCHITECT OR ENGINEER REGISTERED IN THE STATE OF FLORIDA, OR ALTERNATE METHODOLOGIES, APPROVED BY THE STATE OF FLORIDA BUILDING COMMISSION FOR ONE-AND-TWO FAMILY DWELLINGS, FBC 1609.3.1 THRU 1609.3.3.

FOR DESIGN PURPOSES THE FOLLOWING BASIC WIND SPEEDS ARE PER FLORIDA BUILDING CODE FIGURE 1609-A
THROUGH 1609-C ULTIMATE DESIGN WIND SPEEDS FOR RISK CATEGORY AND BUILDINGS AND OTHER STRUCTURES
Revised 7/1/18

Total (Sq. Ft.) under roof

Designers name and signature shall be on all documents and a licensed architect or engineer, signature and official embossed seal

Website: http://www.columbiacountyfla.com/BuildingandZoning.asp

GENERAL REQUIREMENTS:

APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL

All drawings must be clear, concise, drawn to scale, details that are not used shall be marked void

shall be affixed to the plans and documents as per the FLORIDA BUILDING CODES RESIDENTIAL 107.1.

Two (2) complete sets of plans containing the following:

Condition space (Sq. Ft.)

Items to Include-

Each Box shall be

Circled as

Applicable
Select From Drop down

No

NA

Si	te Plan information including:			
4	Dimensions of lot or parcel of land			
5	Dimensions of all building set backs			
6	Location of all other structures (include square footage of structures) on parcel, existing or proposed			
	well and septic tank and all utility easements.			
7	Provide a full legal description of property.			
W	ind-load Engineering Summary, calculations and any details are required.			
	GENERAL REQUIREMENTS:	Items	s to Includ	de-
	APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL		Box shall	be
		Circled as Applicable		
8	Plans or specifications must show compliance with FBCR Chapter 3	Yes	No	NA
		Select Fro	m Drop	down
9	Basic wind speed (3-second gust), miles per hour			
10	(Wind exposure – if more than one wind exposure			
	is used, the wind exposure and applicable wind direction shall be indicated)			
11	Wind importance factor and nature of occupancy			
10		-		\vdash
12	The applicable internal pressure coefficient, Components and Cladding	=======================================		
13	The design wind pressure in terms of psf (kN/m²), to be used for the design of exterior component,	1		
13	cladding materials not specifally designed by the registered design professional.)		
El	evations Drawing including:	1		
14	All side views of the structure			
15	Roof pitch			
16	Overhang dimensions and detail with attic ventilation			
17	Location, size and height above roof of chimneys			
18	Location and size of skylights with Florida Product Approval			
19	Number of stories		1	
20	Building height from the established grade to the roofs highest peak			
				1

Dimensioned area plan showing rooms, attached garage, breeze ways, covered porches, 21 deck, balconies Raised floor surfaces located more than 30 inches above the floor or grade 22 23 All exterior and interior shear walls indicated 24 Shear wall opening shown (Windows, Doors and Garage doors) Show compliance with Section FBCR 310 Emergency escape and rescue opening shown in each bedroom (net clear opening shown) and Show compliance with Section FBC 1405.13.2 where the opening of an operable window is located more than 72 inches above the finished grade or surface below, the lowest part of the clear opening of the window shall be a minimum of 24 inches above the finished floor of the room in which the window is located. Glazing between the floor and 24 inches shall be fixed or have openings through which a 4-inch-diameter sphere cannot pass. Safety glazing of glass where needed 26 Fireplaces types (gas appliance) (vented or non-vented) or wood burning with Hearth 27 (see chapter 10 and chapter 24 of FBCR) Show stairs with dimensions (width, tread and riser and total run) details of guardrails, Handrails 28 Identify accessibility of bathroom (see FBCR SECTION 320) All materials placed within opening or onto/into exterior walls, soffits or roofs shall have Florida product approval number and mfg. installation information submitted with the plans (see Florida product approval form) **GENERAL REQUIREMENTS:** Items to Include-APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL Each Box shall be Circled as Applicable **FBCR 403: Foundation Plans** Select From Drop down Location of all load-bearing walls footings indicated as standard, monolithic, dimensions, size and type of reinforcing. 31 All posts and/or column footing including size and reinforcing 32 Any special support required by soil analysis such as piling. 33 | Assumed load-bearing valve of soil Pound Per Square Foot Location of horizontal and vertical steel, for foundation or walls (include # size and type) For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an grounding electrode system. Per the National Electrical Code article 250.52.3 FBCR 506: CONCRETE SLAB ON GRADE 35 Show Vapor retarder (6mil. Polyethylene with pints la ed 6 inches and sealed) 36 Show control joints, synthetic fiber reinforcement or welded fire fabric reinforcement and Sworts FBCR 318: PROTECTION AGAINST TERMITES Indicate on the foundation plan if soil treatment is used for subterranean termite prevention or Submit other approved termite protection methods. Protection shall be provided by registered termiticides FBCR 606: Masonry Walls and Stem walls (load bearing & shear Walls) 38 Show all materials making up walls, wall height, and Block size, mortar type 39 Show all Lintel sizes, type, spans and tie-beam sizes and spacing of reinforcement

Floor Pl an Including:

Metal frame shear wall and roof systems shall be designed, signed and sealed by Florida Prof. Engineer or Architect

Flo	oor Framing System: First and/or second story			
	Floor truss package shall including layout and details, signed and sealed by Florida Registered			
40	Professional Engineer		1	
	Show conventional floor joist type, size, span, spacing and attachment to load bearing walls,			
41	stem walls and/or priers			
42	Girder type, size and spacing to load bearing walls, stem wall and/or priers			
43	Attachment of joist to girder			
44	Wind load requirements where applicable			
45	Show required under-floor crawl space			
46	Show required amount of ventilation opening for under-floor spaces			
47	Show required covering of ventilation opening			
48	Show the required access opening to access to under-floor spaces			
	Show the sub-floor structural panel sheathing type, thickness and fastener schedule on the edges &			
49	intermediate of the areas structural panel sheathing			1
50	Show Draftstopping, Fire caulking and Fire blocking			
51	Show fireproofing requirements for garages attached to living spaces, per FBCR section 302.6			
52	Provide live and dead load rating of floor framing systems (psf).			
FR	CR CHAPTER 6 WOOD WALL FRAMING CONSTRUCTION			
T.D	CA CILL TEAU WOOD WALDFROMING CONSTRUCTION	Items	to Inclu	de-
	GENERAL REQUIREMENTS:		Box shall	
	APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL		rcled as	
			plicable	
	Se	lect fror	-	
53	Stud type, grade, size, wall height and oc spacing for all load bearing or shear walls			
54	Fastener schedule for structural members per table FBC-R602.3.2 are to be shown			
54	Show wood structural panel's sheathing attachment to studs, joist, trusses, rafters and structural		1	
55				
33	members, showing fastener schedule attachment on the edges & intermediate of the areas structural			
	panel sheathing			
	Show all required connectors with a max uplift rating and required number of connectors and			
56	oc spacing for continuous connection of structural walls to foundation and roof trusses or			
	rafter systems			
	Show sizes, type, span lengths and required number of support jack studs, king studs for			
57	shear wall opening and girder or header per FBC-R602.7.			
58	Indicate where pressure treated wood will be placed		ļ	
	Show all wall structural panel sheathing, grade, thickness and show fastener schedule for structural			
59	panel sheathing edges & intermediate areas		-	
60	A detail showing gable truss bracing, wall balloon framing details or/ and wall hinge bracing detail			
FF	BCR :ROOF SYSTEMS:			
61	Truss design drawing shall meet section FBC-R 802.10. 1 Wood trusses			
62	Include a layout and truss details, signed and sealed by Florida Professional Engineer			
63	Show types of connector's assemblies' and resistance uplift rating for all trusses and rafters			-
64	Show gable ends with rake beams showing reinforcement or gable truss and wall bracing details		1	
65	Provide dead load rating of trusses		ł	-
03	Provide dead load rating of dusses	-		
F	BCR 802:Conventional Roof Framing Layout			
66	Rafter and ridge beams sizes, span, species and spacing			
67	Connectors to wall assemblies' include assemblies' resistance to uplift rating		Tr.	
68	Valley framing and support details	1.0		
69	Provide dead load rating of rafter system			
-	CD coa D C CD CVVI A TVVI C		212	
-	SCR 803 ROOF SHEATHING		1	
70	Include all materials which will make up the roof decking, identification of structural panel		1	

sheathing, grade, thickness
71 Show fastener Size and schedule for structural panel sheathing on the edges & intermediate areas

ROOF ASSEMBLIES FRC Chapter 9

72	Include all materials which will make up the roof assembles covering		
73	Submit Florida Product Approval numbers for each component of the roof assembles covering		

FBCR Chapter 11 Energy Efficiency Code for Residential Building

Residential construction shall comply with this code by using the following compliance methods in the FBCR Chapter 11 Residential buildings compliance methods. Two of the required forms are to be submitted, N1100.1.1.1 As an alternative to the computerized Compliance Method A, the Alternate Residential Point System Method hand calculation, Alternate Form 600A, may be used. All requirements specific to this calculation are located in Sub appendix C to Appendix G. Buildings complying by this alternative shall meet all mandatory requirements of this chapter. Computerized versions of the Alternate Residential Point System Method shall not be acceptable for code compliance.

i	GENERAL REQUIREMENTS: APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL	Each E	Box shall reled as plicable	l be
		Select from	Drop	Down
74	Show the insulation R value for the following areas of the structure			
75	Attic space			
76	Exterior wall cavity			
77	Crawl space			
H	VAC information			
7 8				
79	Exhaust fans shown in bathrooms Mechanical exhaust capacity of 50 cfm intermittent or			
	20 cfm continuous required			
80	Show clothes dryer route and total run of exhaust duct			
ъ.				
	umbing Fixture layout shown			
	All fixtures waste water lines shall be shown on the foundationplan			<u> </u>
82	Show the location of water heater		l i	
D.	ivate Potable Water			
			r - i	
	Pump motor horse power	-		5
	Reservoir pressure tank gallon capacity			
85	Rating of cycle stop valve if used			
FL	ectrical layout shown including			
86	Show Switches, receptacles outlets, lighting fixtures and Ceiling fans	1		
87	Show all 120-volt, single phase, 15- and 20-ampere branch circuits outlets required to be protected	1	- x	-
0 /	by Ground-Fault Circuit Interrupter (GFCI) Article 210.8 A	1		
88	Show the location of smoke detectors & Carbon monoxide detectors			
89	Show service panel, sub-panel, location(s) and total ampere ratings			
0)	Show service paner, sub-paner, rocation(s) and total ampere ratings			
	On the electrical plans identify the electrical service overcurrent protection device for the main			
	electrical service. This device shall be installed on the exterior of structures to serve as a			
on	disconnecting means for the utility company electrical service. Conductors used from the exterior			
90	disconnecting means for the utility company electrical service. Conductors used from the exterior			
90	disconnecting means to a panel or sub panel shall have four-wire conductors, of which one			
90	disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance			
90	disconnecting means to a panel or sub panel shall have four-wire conductors, of which one			
90	disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type.			Į.
90	disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type. For structures with foundation which establish new electrical utility companies service			
90	disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type. For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an			
	disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type. For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an Grounding electrode system. Per the National Electrical Code article 250.52.3			
91	disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type. For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an Grounding electrode system. Per the National Electrical Code article 250.52.3 Appliances and HVAC equipment and disconnects			
91	disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type. For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an Grounding electrode system. Per the National Electrical Code article 250.52.3 Appliances and HVAC equipment and disconnects Show all 120-volt, single phase, 15- and 20-ampere branch circuits supplying outlets installed			
90 91 92	disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type. For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an Grounding electrode system. Per the National Electrical Code article 250.52.3 Appliances and HVAC equipment and disconnects Show all 120-volt, single phase, 15- and 20-ampere branch circuits supplying outlets installed in dwelling unit family rooms, dining rooms, living rooms, parlors, libraries, dens, bedrooms,			
91	disconnecting means to a panel or sub panel shall have four-wire conductors, of which one conductor shall be used as an equipment ground. Indicate if the utility company service entrance cable will be of the overhead or underground type. For structures with foundation which establish new electrical utility companies service connection a Concrete Encased Electrode will be required within the foundation to serve as an Grounding electrode system. Per the National Electrical Code article 250.52.3 Appliances and HVAC equipment and disconnects Show all 120-volt, single phase, 15- and 20-ampere branch circuits supplying outlets installed			

Items to Include-

Notice Of Commencement:

A notice of commencement form RECORDED in the Columbia County Clerk Office is required to be filed with the Building Department BEFORE ANY INSPECTIONS can be performed.

GENERAL REQUIREMENTS: APPLICANT – PLEASE CHECK ALL APPLICABLE BOXES BEFORE SUBMITTAL

Items to Include-Each Box shall be Circled as Applicable

ITEMS 95, 96, & 98 Are Required After APPROVAL from the ZONING DEPT.

Select from Drop down

	i a company and a company	Select from	Drop o	down
93	Building Permit Application A current Building Permit Application is to be completed,			
U.	by following the Checklist all supporting documents must be submitted.			
	There is a \$15.00 application fee. The completed application with attached documents and application			
	fee can be mailed.			
94	Parcel Number The parcel number (Tax ID number) from the Property Appraisers Office			
	(386) 758-1083 is required. A copy of property deed is also required. www.columbiacountyfla.com			
95	Environmental Health Permit or Sewer Tap Approval A copy of a approved			
	Columbia County Environmental Health (386) 758-1058	- 4		
96	City of Lake City A City Water and/or Sewer letter. Call 386-752-2031			
97	Toilet facilities shall be provided for all construction sites			
98	Town of Fort White (386) 497-2321 If the parcel in the application for building permit is		3	
	within the Corporate city limits of Fort White, an approval land use development letter issued by the			
	Town of Fort is required to be submitted with the application for a building permit.			
99	Flood Information: All projects within the Floodway of the Suwannee or Santa Fe Rivers			
	shall require permitting through the Suwannee River Water Management District, before submitting			
	a application to this office. Any project located within a flood zone where the base flood			
	elevation (100 year flood) has been established shall meet the requirements of Section 8.5.2 of the			
	Columbia County Land Development Regulations. Any project located within a flood zone			
	where the base flood elevation has not been established (Zone A) shall meet the requirements of			
	Section 8.5.3 of the Columbia County Land Development Regulations (Municode.com)		-	
100	CERTIFIED FINISHED FLOOR ELEVATIONS will be required on any project where the approved		1 1	
	FIRM Flood Maps show the property is in a AE, Floodway, and AH flood zones. Additionally One Foot			
	Rise letters are required for AE and AH zones. In the Floodway Flood zones a Zero Rise letter is required		-	
101	A Flood development permit is also required for AE, Floodway & AH. Development permit cost is \$50.0	00	-	
	Driveway Connection: If the property does not have an existing access to a public road, then			
100	an application for a culvert permit (\$25.00) must be made. County Public Works Dept. determines the size			
102	and length of every culvert before instillation and completes a final inspection before permanent power is granted.	i i		
	If the applicant feels that a culvert is not needed, they may apply for a culvert waiver (\$50.00) Separate			
	Check when issued. If the project is to be located on an F.D.O.T. maintained road, then an F.D.O.T. access permit is required.			
		_		_
103	911 Address: An application for a 911 address must be applied for and received through the Columbia	·		
105	County Emergency Management Office of 911 Addressing Department (386) 758-1125.			
		,		

Ordinance Sec. 90-75. - Construction debris. (e) It shall be unlawful for any person to dispose of or discard solid waste, including construction or demolition debris at any place within the county other than on an authorized disposal site or at the county's solid waste facilities. The temporary storage, not to exceed seven days of solid waste (excluding construction and demolition debris) on the premises where generated or vegetative trash pending disposition as authorized by law or ordinance, shall not be deemed a violation of this section. The temporary storage of construction and demolition debris on the premises where generated or vegetative trash pending disposition as authorized by law or ordinance shall not be deemed in violation of this section; provided, however, such construction and demolition debris must be disposed of in accordance with this article prior to the county's issuance of a certificate of occupancy for the premises. The burning of lumber from a construction or demolition project or vegetative trash when done so with legal and proper permits from the authorized agencies and in accordance with such agencies' rules and regulations, shall not be deemed a violation of this section. No person shall bury, throw, place, or deposit, or cause to be buried, thrown, placed, or deposited, any solid waste, special waste, or debris of any kind into or on any of the public streets, road right-of-way, highways, bridges, alleys, lanes, thoroughfares, waters, canals, or vacant lots or lands within the county. No person shall bury any vegetative trash on any of the public streets, road right-of-way, highways, bridges, lanes, thoroughfares, waters, canals, or lots less than ten acres in size within the county.

Disclosure Statement for Owner Builders:

If you as the Applicant will be acting as your own contractor or owner/builder under section 489.103(7) Florida Statutes, you must submit the required notarized Owner Builder Disclosure Statement form.

**This form can be printed from the Columbia County Website on the Building and Zoning page under Documents. Web address is - http://www.columbiacountyfla.com/BuildingandZoning.asp

Section 105 of the Florida Building Code defines the:

Time limitation of application.

An application for a permit for any proposed work shall be deemed to have been abandoned 180 days after the date of filing, unless such application has been pursued in good faith or a permit has been issued; except that the building official is authorized to grant one or more extensions of time for additional periods not exceeding 90 days each. The extension shall be requested in writing and justifiable cause demonstrated.

Single-family residential dwelling.

Section 105.3.4 A building permit for a single-family residential dwelling must be issued within 30 working days of application therefor unless unusual circumstances require a longer time for processing the application or unless the permit application fails to satisfy the Florida Building Code or the enforcing agency's laws or ordinances.

Permit intent.

Section 105.4.1: A permit issued shall be constructed to be a license to proceed with the work and not as authority to violate, cancel, alter or set aside any of the provisions of the technical codes, nor shall issuance of a permit prevent the building official from thereafter requiring a correction of errors in plans, construction or violations of this code. Every permit issued shall become invalid unless the work authorized by such permit is commenced within six months after its issuance, or if the work authorized by such permit is suspended or abandoned for a period of six months after the time the work is commenced.

If work has commenced.

Section 105.4.1.1: If work has commenced and the permit is revoked, becomes null and void, or expires because of lack of progress or abandonment, a new permit covering the proposed construction shall be obtained before proceeding with the work.

New Permit.

Section 105.4.1.2: If a new permit is not obtained within 180 days from the date the initial permit became null and void, the building official is authorized to require that any work which has been commenced or completed be removed from the building site. Alternately, a new permit may be issued on application, providing the work in place and required to complete the structure meets all applicable regulations in effect at the time the initial permit became null and void and any regulations which may have become effective between the date of expiration and the date if issuance of the new permit.

Work Shall Be:

Section 105.4.1.3: Work shall be considered to be in active progress when the permit has received an approved inspection within 180 days. This provision shall not be applicable in case of civil commotion or strike or when the building work is halted due directly to judicial injunction, order or similar process.

The Fee:

Section 105.4.1.4: The fee for renewal reissuance and extension of a permit shall be set forth by the administrative authority.

Notification:

When the application is approved for permitting the applicant will be notified by phone as to the status by the Columbia County Building & Zoning Department.