

2632 NW 43 St.
Suite 2186
Gville, 32606

FIELD DENSITY WORKSHEET

CLIENT Jaspertone Builders & Const. mgmt.

DATE 10/11/22

PROJECT NAME 282 SW Kimberly LN

PROJECT NO. _____

EARTH CONTRACTOR _____

PERMIT NO. #000044792

COMPACTION REQUIREMENT (%) 95

☐ Standard Proctor

TESTED BY AC

☒ Modified Proctor

FIELD CONTACT _____

TOTAL ON-SITE TIME _____

MILES FROM OFFICE _____

☐ Limerock ☐ Subgrade ☐ Pipe Backfill ☒ Building Pad ☐ Building Footing ☐ Other _____

TEST LOCATION	LAB PROCTOR		TEST DEPTH	PROBE DEPTH	% MOIST.	WET DENSITY (PCF)	DRY DENSITY (PCF)	% COMP.
	DENS.	OMC						
App 5' W of E corner	103.9	14.2	F6	12"	7.8	109.0	101.1	97.3
App center	↓	↓	↓	↓	6.1	108.0	101.8	98.0
App 5' E of W corner	↓	↓	↓	↓	7.3	107.5	100.2	96.4

REMARKS no permit box

- * Density failed to meet minimum project requirement
- ** Retest indicates minimum density requirement was obtained.
- () Client is aware of unsatisfactory test results.