

**Mark D. Duren and
Associates, Inc.
Professional Surveyor and Mapper**

1604 SW SISTERS WELCOME ROAD
Lake City, FL 32025
386-758-9831 Phone
386-758-8010 Fax
mddpsm@markduren.com
jldmddpsm@gmail.com

October 12, 2021

IE. Floor Elevation of structure on Tax Parcel No. 22-4S-16-03087-114

To Whom It May Concern,

A minimum floor elevation of 110.70 feet, National Geodetic vertical Datum of 1929, was established for the above referenced parcel according to the plat of record for "FOREST COUNTRY 6TH ADDITION", plat book 9, pages 66-67, prepared by Britt Surveying

The elevation of the STEM WALLS of the structure under construction is 110.04 feet, NGVD 1929 Datum. The elevation of the centerline of SW Short Leaf Drive in front of the structure is 108.18 feet NGVD 1929 Datum.



Mark D. Duren, LS 4703

