

February 7, 2019

Aaron Simque Homes
333 SW Rosemary Drive
Lake City, FL 32025

**Subject: Permit #37141 - Lots 121 & 122, Preserve at Laurel Lake, Unit 1 -
Elevation Letter**

Dear Aaron:

Daniel & Gore, LLC has performed a vertical survey on Lots 121 & 122, Preserve at Laurel Lake, Unit 1, Columbia County, Florida from a benchmark being a 60d nail at the common lot line between Lots 8 & 9 (elevation – 116.12', NGVD 1929) and have determined the following:

- The Subdivision plat requires the minimum finish floor elevation to be 118.3'.
- The finish floor elevation of the foundation is at 119.0', being 0.7' above the minimum finish floor requirement.

If you have any questions, please call me.

Sincerely,



Scott Daniel, PSM