




**C** ELEVATION DETAIL - EMERGENCY DEPARTMENT CANOPY @ ENTRANCE - SIGN LOCATION - EXT-01  
SCALE: 1/4" - 1'-0"



**D** ELEVATION DETAIL - SIGN TYPE EXT-A - INTERNALLY ILLUMINATED CHANNEL LETTERS, RACEWAY MOUNTED  
SCALE: 1/2" - 1'-0"

NOTE: TEXT T4; FABRICATED CHANNEL LETTERS WITH ACRYLIC FACES AND PAINTED RETURNS; INTERNALLY ILLUMINATED WITH LEDS AS REQUIRED FOR SUFFICIENT ILLUMINATION AND NO HOTS SPOTS. COORDINATE LOCATION OF REQUIRED POWER AND ANY BLOCKING WITH GC; FINAL ELECTRICAL CONNECTION OF SIGN TO POWER BY SIGN CONTRACTOR/INSTALLER; RACEWAY PAINTED TO MATCH SCHEDULED MOUNTING SURFACE.

REFER TO HCA SIGN GUIDELINES FOR SPECIFIC DETAILS OF MATERIALS AND METHODS FOR APPLICATION IF INTERNALLY ILLUMINATED CHANNEL LETTERS.



MATERIAL	DESCRIPTION
M1	ALUMINUM RETURNS AND BACKS. FINISH TO BE T.B.D. INSIDE OF LETTERS TO BE WHITE.
M2	1" RED JEWELITE TRIM-CAPS.
M3	RED PLASTIC FACES.
M4	WHITE L.E.D. STRIPS MOUNTED INSIDE OF LETTERS.
M5	FLEX CONDUIT.
M6	L.E.D. STRIPS TO BE MOUNTED TO RETURNS OR BACKS OF CHANNEL LETTERS WITH V.H.B. TAPE AND SILICONE.
M7	1/4" WEEP HOLES AS REQUIRED.
M8	MOUNTING HARDWARE (TYPE TO BE DETERMINED BY WALL CONSTRUCTION).
M9	(120 VOLT) L.E.D. POWER SUPPLIES INSIDE OF RACEWAY.
M10	DISCONNECT SWITCH.
M11	PRIMARY ELECTRICAL LEADS, POWER TO SIGN BY OTHERS.
M12	ALUMINUM RACEWAY. FINISH TO BE SPRAYED TO MATCH BUILDING.

ANCHOR SCHEDULE		QTY or SPACING
WALL MATERIAL	ANCHOR TYPE	
CONCRETE (3ksi) or HOLLOW MASONRY	1/4" THREADED RODS WITH MIN 2" EMBED IN ADHESIVE	--NOT APPLICABLE--
	1/4" TAPCONS (OR EQUIV) WITH 1.75" EMBED	PAIRS AT 48" O.C.
	1/4" EXPANSION ANCHORS WITH 2.5" EMBED	PAIRS AT 48" O.C.
1/2" PLYWOOD (NO ACCESS BEHIND)	1/4" TOGGLE BOLTS	PAIRS AT 48" O.C.
	1/4" WOOD SCREWS, FULL EMBED	PAIRS AT 48" O.C.
METAL STUDS / PANELS	#14 METAL SCREWS TO MIN 18ga STEEL OR 0.090" ALUM	PAIRS AT 48" O.C.
HOLLOW WALL + BLOCKING	1/4" THRU BOLTS OR LAGS TO SOLID BLOCKING BEHIND	PAIRS AT 48" O.C.

**Project:** HCA Florida Lake City Hospital

**Location:** 340 NW Commerce Dr, Lake City, FL 32055

This is an Original Drawing Provided as Part of a Planned Project and is Not to be Exhibited, Copied Or Reproduced Without the Written Permission of Architectural Identification Inc. or it's Authorized Agents. All Rights Reserved.

**Date:** 12-9-22

**Scale:** As Noted

**Customer Approval:**

**Project Manager:**  
Trent M. Eckfeld  
**Drawn By:** JWC

**architectural  
identification  
incorporated**

**Corporate Office:**  
1170 Claycraft Road  
Gahanna, OH 43230  
Tel: 614-868-8400

**Florida Branch Office:**  
2105 Tyrone Blvd. N.  
St. Petersburg, FL 33710  
Tel: 727-851-9544